

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

March 13, 2014

WIESER CONCRETE PRODUCTS, INC. MARK WIESER 2815 RILEY ROAD PORTAGE WI 53901

Re: Description: SEWAGE TANKS, CONCRETE

Manufacturer: WIESER CONCRETE PRODUCTS, INC.

Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, SEPTIC/SIPHON OR HOLDING

Model Number(s): W3800/2200

(49/48" L.L, 78/45 GAL/IN., 96" MAx. DEPTH OF BURY, 2875 G.P.D. WHEN USED AS A

SEPTIC/SEPTIC TANK OR 1827 G.P.D. WHEN USED AS A SEPTIC/PUMP OR SEPTIC/SIPHON TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL

WASTEWATER; TANK DIMENSIONS (OD) = 238 IN. L X 142 IN. W X 78 IN. H)

Product File No: 20140036

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2019.** 

This approval supersedes the approval issued on 3/04/2009 under product file number 20090086.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- When this product has an inlet baffle located in the second compartment, an inspection, service, maintenance opening shall be provided over the baffle in accordance with s. SPS 384.25 (7)(a) of the Wisconsin Administrative Code.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S. POWTS Product Reviewer phone: (608) 267-5265 fax: (608) 267-9723 email: glen.jones@wi.gov

SBD-10564-E (N.10/97) File Ref: 14003601.DOC